



Certificate Ref: **PDCERT2307070001**

Portable Power Distribution Unit Test and Inspection Certification									
Distribution Board Serial Number or ID				MD400365RCBO0153					
Appliance inlet type		PowerLock		Rating (A)		400		1ph	
Loop through outlet type		PowerLock		Rating (A)		400		1ph	
Does the loop through output have on board protection				YES				NO	
Main Switch / Switch Fuse/ Circuit Breaker / RCD									
BS(EN)		60947		Breaking Capacity (KA)		18			
No of Poles		4		Fuse /Device rating or setting (A)		400			
If Main Switch is RCD									
Rated residual operating current (ma)				Rated Time delay (ms)		N/A			
Operating time (ms)		X1		X5				ma	
Visual Inspection Satisfactory				Yes		x		No	
If No Give details				L1=Brown L2=Black L3=Gray					
Functional Testing									
Do all MCBs maually operate correctly				YES		x		NO	
If No Give details									
Do all RCD test buttons operate correctly				YES		x		NO	
If No Give details									
Do all circuit indicators operate correctly				YES		x		NO	
If No Give details				N/A					
Insulation Resistance Tested at 250V due to sensitive equipment									
L1 - CPC		1.6 Mohm		Satisfactory		x		Yes	
L2 - CPC		2.6 Mohm		Satisfactory		x		Yes	
L3 - CPC		2.55 Mohm		Satisfactory		x		Yes	
N-CPC		1.9 Mohm		Satisfactory		x		Yes	
Polarity throughout Satisfactory				Yes				No	
Test Instrument serial number				1009986102219630					
Inspected By				1009986102219630 Dubai - U.A.E.					
Name		Pierre		Umar					
Signature				Date		2023-07-07			

Certificate Ref: PDCERT2307070001

Scheduled of Results														
Distribution Board Serial Number or ID								MD400365RCBO0153						
Circuit Number	RCBO							Test results					Remarks (Continue on separate sheet if necessary)	
	Over current device				RCD									
	BS(EN)	Type (B,C,D)	Rating (A)	Breaking Capacity (KA)	BS(EN)	Rating (mA)	Time delay (ms)	RCD trip time x 1/2 (ms)	RCD trip time x 1 (ms) <300	RCD ramp test (mA)	Polarity	Test button operation		
Out1	61009	C	10	6	61009	30	0	>99	8.9	21	✓	✓		
Out2	61009	C	10	6	61009	30	0	>99	9	19	✓	✓		
Out3	61009	C	10	6	61009	30	0	>99	9.1	21	✓	✓		
Out4	61009	C	10	6	61009	30	0	>99	9	21	✓	✓		
Out5	61009	C	10	6	61009	30	0	>99	9	21	✓	✓		
Out6	61009	C	10	6	61009	30	0	>99	9	21	✓	✓		
Out7	61009	C	16	6	61009	30	0	>99	23.3	19	✓	✓		
Out8	61009	C	16	6	61009	30	0	>99	23.6	19	✓	✓		
Out9	61009	C	16	6	61009	30	0	>99	23.6	21	✓	✓		
Out10	61009	C	16	6	61009	30	0	>99	23.1	19	✓	✓		
Out11	61009	C	16	6	61009	30	0	>99	23.5	19	✓	✓		
Out12	61009	C	16	6	61009	30	0	>99	23.4	19	✓	✓		
														
Out13		A	40	10	61008	30	0	>99			✓	✓		
1	60898	C	32	6			0	>99	29.2	23	✓	✓		
2	60898	C	32	6			0	>99	29.3	25	✓	✓		
3	60898	C	32	6			0	>99	29.3	23	✓	✓		
Out14		A	40	10	61008	30	0	>99			✓	✓		
1	60898	C	32	6			0	>99	28.5	23	✓	✓		
2	60898	C	32	6			0	>99	28.8	23	✓	✓		
3	60898	C	32	6			0	>99	28.5	23	✓	✓		

Out15		A	40	10	61008	30	0	>99			√	√	
1	60898	C	32	6			0	>99	28.4	19	√	√	
2	60898	C	32	6			0	>99	28.3	19	√	√	
3	60898	C	32	6			0	>99	28.5	19	√	√	
Out16		A	40	10	61008	30	0	>99			√	√	
1	60898	C	32	6			0	>99	29.4	21	√	√	
2	60898	C	32	6			0	>99	29.5	21	√	√	
3	60898	C	32	6			0	>99	29.4	21	√	√	
Out17		A	40	10	61008	30	0	>99			√	√	
1	60898	C	32	6			0	>99	29	19	√	√	
2	60898	C	32	6			0	>99	28.7	19	√	√	
3	60898	C	32	6			0	>99	28.6	19	√	√	
Out18		A	40	10	61008	30	0	>99			√	√	
1	60898	C	32	6			0	>99	29	25	√	√	
2	60898	C	32	6			0	>99	28.7	21	√	√	
3	60898	C	32	6			0	>99	28.6	21	√	√	
Out19		A	63	10	61008	30	0	>99			√	√	
1	60898	C	63	6			0	>99	25.3	21	√	√	
2	60898	C	63	6			0	>99	24.4	21	√	√	
3	60898	C	63	6			0	>99	25.4	21	√	√	
Out20		A	63	10	61008	30	0	>99			√	√	
1	60898	C	63	6			0	>99	25.5	25	√	√	
2	60898	C	63	6			0	>99	25.5	21	√	√	
3	60898	C	63	6			0	>99	25.6	21	√	√	
Out21	60898	C	125	16			0	>99			√	√	
Out22	60898	C	125	16			0	>99			√	√	
Inspected By													
Name	Pierre			Umair									
Signature				Date	2023-07-07								
Test Instrument details : Serial number					Megger MFT1741 1009986102219630								