


Certificate Ref: **PDCERT2307050006**

Portable Power Distribution Unit Test and Inspection Certification									
Distribution Board Serial Number or ID				MD32130RCD0158					
Appliance inlet type		Not A/V		Rating (A)		1ph		3ph	
Loop through outlet type		Not A/V		Rating (A)		1ph		3ph	
Does the loop through output have on board protection						YES		NO	
Main Switch / Switch Fuse/ Circuit Breaker / RCD									
BS(EN)		Not A/V		Breaking Capacity (KA)					
No of Poles				Fuse /Device rating or setting (A)					
If Main Switch is RCD									
Rated residual operating current (ma)				Rated Time delay (ms)		N/A			
Operating time (ms)		X1		X5		ma			
Visual Inspection Satisfactory				Yes		x		No	
If No Give details									
Functional Testing									
Do all MCBs maually operate correctly				YES		x		NO	
If No Give details									
Do all RCD test buttons operate correctly				YES		x		NO	
If No Give details									
Do all circuit indicators operate correctly				YES		x		NO	
If No Give details									
Insulation Resistance Tested at 250V due to sensitive equipment									
L1 - CPC		1.5		Mohm		Satisfactory		x	
L2 - CPC		2		Mohm		Satisfactory		x	
L3 - CPC		2		Mohm		Satisfactory		x	
N-CPC		1.8		Mohm		Satisfactory		x	
Polarity throughout Satisfactory				Yes		x		No	
Test Instrument serial number				1009986102219636					
Inspected By									
Name		Pierre							
Signature				Date		2023-05-07			



Certificate Ref: PDCERT2307050006

Schedule of Results													
Distribution Board Serial Number or ID								DB32130RCD0158					
RCBO													
Circuit Number	Over current device				RCD			Test results				Remarks (Continue on separate sheet if necessary)	
	BS(EN)	Type (B,C,D)	Rating (A)	Breaking Capacity (KA)	BS(EN)	Rating (mA)	Time delay (ms)	RCD trip time x 1/2 (ms)	RCD trip time x 1 (ms) <300	RCD ramp test (mA)	Polarity		Test button operation
Out1		A	40	10	61008	30	0	>99			✓	✓	
1	60898	C	32	6			0	>99	28.6	19	✓	✓	
2	60898	C	32	6			0	>99	28.7	19	✓	✓	
3	60898	C	32	6			0	>99	28.6	19	✓	✓	
Inspected By Name Pierre Signature  Date 2023-05-07													
Test Instrument details : Serial number Megger MFT1741 1009986102219630													

