



Certificate Ref: **PDCERT2309080012**

Portable Power Distribution Unit Test and Inspection Certification									
Distribution Board Serial Number or ID				DBR323P0220154					
Appliance inlet type		C-Form		Rating (A)	32	1ph	X	3ph	
Loop through outlet type		C-Form		Rating (A)	32	1ph	X	3ph	X
Does the loop through output have on board protection					YES		NO		X
Main Switch / Switch Fuse/ Circuit Breaker / RCD									
BS(EN)				Breaking Capacity (KA)					
No of Poles				Fuse /Device rating or setting (A)					
If Main Switch is RCD									
Rated residual operating current (ma)				Rated Time delay (ms)		N/A			
Operating time (ms)		X1		X5				ma	
Visual Inspection Satisfactory				Yes	X	No	L1=Brown		
If No Give details									
Functional Testing									
Do all MCBs maually operate correctly				YES		NO			
If No Give details									
Not available									
Do all RCD test buttons operate correctly				YES		NO			
If No Give details									
Not available									
Do all circuit indicators operate correctly				YES	X	NO		N/A	
If No Give details									
Insulation Resistance Tested at 250V due to sensitive equipment									
L1 - CPC		Mohm	Satisfactory	X	Yes		No		
L2 - CPC		Mohm	Satisfactory	X	Yes		No		
L3 - CPC		Mohm	Satisfactory	X	Yes		No		
N-CPC		Mohm	Satisfactory	X	Yes		No		
Polarity throughout Satisfactory				Yes		No			
Test Instrument serial number				1009986102219630					
Inspected By									
Name		Pierre							
Signature				Date	2023-08-09				