


Certificate Ref: **PDCERT2309080014**

Portable Power Distribution Unit Test and Inspection Certification									
Distribution Board Serial Number or ID				SB165P06C163P0152					
Appliance inlet type		C-Form		Rating (A)		16		1ph	
Loop through outlet type		C-Form		Rating (A)		16		1ph	
Does the loop through output have on board protection				YES				NO	
Main Switch / Switch Fuse/ Circuit Breaker / RCD									
BS(EN)				Breaking Capacity (KA)					
No of Poles				Fuse /Device rating or setting (A)					
If Main Switch is RCD									
Rated residual operating current (ma)				Rated Time delay (ms)		N/A			
Operating time (ms)		X1		X5		ma			
Visual Inspection Satisfactory				Yes		x		No	
If No Give details									
Functional Testing									
Do all MCBs maually operate correctly				YES				NO	
If No Give details									
Not available									
Do all RCD test buttons operate correctly				YES				NO	
If No Give details									
Not available									
Do all circuit indicators operate correctly				YES		x		NO	
If No Give details									
Insulation Resistance Tested at 250V due to sensitive equipment									
L1 - CPC		Mohm		Satisfactory		x		Yes	
L2 - CPC		Mohm		Satisfactory		x		Yes	
L3 - CPC		Mohm		Satisfactory		x		Yes	
N-CPC		Mohm		Satisfactory		x		Yes	
Polarity throughout Satisfactory				Yes				No	
Test Instrument serial number				1009986102219630					
Inspected By									
Name		Pierre		Date		2023-08-09			
Signature									