

Certificate Ref: **PDCERT2312300001**

Portable Power Distribution Unit Test and Inspection Certification													
Distribution Board Serial Number or ID				MD63380RCD0153									
Appliance inlet type		C-Form		Rating (A)		63		1ph		3ph		x	
Loop through outlet type		C-Form		Rating (A)		63		1ph		3ph		x	
Does the loop through output have on board protection						YES				NO		x	
Main Switch / Switch Fuse/ Circuit Breaker / RCD													
BS(EN)		60898		Breaking Capacity (KA)		6							
No of Poles		4		Fuse /Device rating or setting (A)		63							
If Main Switch is RCD													
Rated residual operating current (ma)				Rated Time delay (ms)				N/A					
Operating time (ms)		X1		X5				ma					
Visual Inspection Satisfactory				Yes		x		No		L1=BROWN, L2=BLACK, L3=GRAY			
If No Give details													
Functional Testing													
Do all MCBs maually operate correctly				YES		x		NO					
If No Give details													
Do all RCD test buttons operate correctly				YES		x		NO					
If No Give details													
Do all circuit indicators operate correctly				YES		x		NO		N/A			
If No Give details													
Insulation Resistance Tested at 250V due to sensitive equipment													
L1 - CPC		1.6		Mohm		Satisfactory		x		Yes		No	
L2 - CPC		2.6		Mohm		Satisfactory		x		Yes		No	
L3 - CPC		2.55		Mohm		Satisfactory		x		Yes		No	
N-CPC		1.9		Mohm		Satisfactory		x		Yes		No	
Polarity throughout Satisfactory				Yes				No					
Test Instrument serial number				1009986102219630									
Inspected By													
Name		Maroun											
Signature				Date		30/12/2023							

Certificate Ref: PDCERT2312300001

Schedule of Results

Distribution Board Serial Number or ID

S/N MD63380RCD0153

	RCBO							Test results					Remarks (Continue on separate sheet if necessary)
	Over current device				RCD								
Circuit Number	BS(EN)	Type (B,C,D)	Rating (A)	Breaking Capacity (KA)	BS(EN)	Rating (mA)	Time delay (ms)	RCD trip time x 1/2 (ms)	RCD trip time x 1 (ms) <300	RCD ramp test (mA)	Polarity	Test button operation	
Out1		A	40	10	61008	30	0	>99			✓	✓	
1	60898	C	16	6			0	>99	25.1	23	✓	✓	
2	60898	C	16	6			0	>99	24.7	23	✓	✓	
3	60898	C	16	6			0	>99	24.7	21	✓	✓	
4	60898	C	32	6			0	>99	24.8	23	✓	✓	
5	60898	C	32	6			0	>99	24.6	21	✓	✓	
6	60898	C	32	6			0	>99	24.8	21	✓	✓	
Out2		A	40	10	61008	30	0	>99			✓	✓	
1	60898	C	16	6			0	>99	24.3	21	✓	✓	
2	60898	C	16	6			0	>99	24.1	21	✓	✓	
3	60898	C	16	6			0	>99	24.1	21	✓	✓	
Out3		A	40	10	61008	30	0	>99			✓	✓	
1	60898	C	16	6			0	>99	24.5	21	✓	✓	
2	60898	C	16	6			0	>99	24.2	21	✓	✓	
3	60898	C	16	6			0	>99	24.4	21	✓	✓	
Out4		A	40	10	61008	30	0	>99			✓	✓	
1	60898	C	16	6			0	>99	26.1	23	✓	✓	
2	60898	C	16	6			0	>99	25.3	25	✓	✓	
3	60898	C	16	6			0	>99	25.5	21	✓	✓	



Out5		A	40	10	61008	30	0	>99			✓	✓	
1	60898	C	16	6			0	>99	25	23	✓	✓	
2	60898	C	16	6			0	>99	24.9	21	✓	✓	
3	60898	C	16	6			0	>99	25	25	✓	✓	
Out6		A	40	10	61008	30	0	>99			✓	✓	
1	60898	C	32	6			0	>99	24.5	23	✓	✓	
2	60898	C	32	6			0	>99	24.3	21	✓	✓	
3	60898	C	32	6			0	>99	24.4	21	✓	✓	
Out7		A	40	10	61008	30	0	>99			✓	✓	
1	60898	C	32	6			0	>99	25.1	21	✓	✓	
2	60898	C	32	6			0	>99	24.6	21	✓	✓	
3	60898	C	32	6			0	>99	24.6	21	✓	✓	

Inspected By			
Name	Maroun	Usman	
Signature		Date	30/12/2023



Test Instrument details : Serial number	Megger MFT1741 1009986102219630
--	---------------------------------