


Certificate Ref: **PDCERT2306160002**

Portable Power Distribution Unit Test and Inspection Certification									
Distribution Board Serial Number or ID				MD32081RCD0154					
Appliance inlet type				Rating (A)				1ph	3ph
Loop through outlet type				Rating (A)				1ph	3ph
Does the loop through output have on board protection							YES		NO X
Main Switch / Switch Fuse/ Circuit Breaker / RCD									
BS(EN)				Breaking Capacity (KA)					
No of Poles				Fuse /Device rating or setting (A)					
If Main Switch is RCD									
Rated residual operating current (ma)			Rated Time delay (ms)			N/A			
Operating time (ms)		X1		X5				ma	
Visual Inspection Satisfactory				Yes	x	No	L1=BROWN, L2=BLACK, L3=GRE		
If No Give details									
Functional Testing									
Do all MCBs maually operate correctly				YES	x	NO			
If No Give details									
Do all RCD test buttons operate correctly				YES	x	NO			
If No Give details									
Do all circuit indicators operate correctly				YES	x	NO	N/A		
If No Give details									
Insulation Resistance Tested at 250V due to sensitive equipment									
L1 - CPC	3.6	Mohm	Satisfactory	x	Yes		No		
L2 - CPC	3.4	Mohm	Satisfactory	x	Yes		No		
L3 - CPC	3.3	Mohm	Satisfactory	x	Yes		No		
N-CPC	2.1	Mohm	Satisfactory	x	Yes		No		
Polarity throughout Satisfactory				Yes		No			
Test Instrument serial number				1009986102219630					
Inspected By									
Name		Pierre							
Signature				Date		16/6/2023			

Certificate Ref: PDCERT2306160002

Schedule of Results													
Distribution Board Serial Number or ID								DB32081RCD0154					
Circuit Number	RCBO				RCD			Test results					Remarks (Continue on separate sheet if necessary)
	Over current device				BS(EN)	Rating (mA)	Time delay (ms)	RCD trip time x 1/2 (ms)	RCD trip time x 1 (ms) <300	RCD ramp test (mA)	Polarity	Test button operation	
	BS(EN)	Type (B,C,D)	Rating (A)	Breaking Capacity (KA)									
Out1		A	40	10	61008	30	0	>99			✓	✓	
1	60898	C	16	6			0	>99	26	25	✓	✓	
2	60898	C	16	6			0	>99	25.9	25	✓	✓	
3	60898	C	16	6			0	>99	25.7	23	✓	✓	
4	60898	C	16	6			0	>99	25.6	25	✓	✓	
5	60898	C	16	6			0	>99	25.7	25	✓	✓	
6	60898	C	16	6			0	>99	25.5	21	✓	✓	
Inspected By													
Name	Pierre												
Signature			Date	16/6/2023									
Test Instrument details : Serial number				Megger MFT1741 1009986102219630									

