



Certificate Ref: **PDCERT2308190002**

Portable Power Distribution Unit Test and Inspection Certification										
Distribution Board Serial Number or ID				DB32081RCD0169						
Appliance inlet type		32		Rating (A)		1ph		3ph		X
Loop through outlet type		32		Rating (A)		1ph		3ph		X
Does the loop through output have on board protection						YES		NO		X
Main Switch / Switch Fuse/ Circuit Breaker / RCD										
BS(EN)				Breaking Capacity (KA)						
No of Poles				Fuse /Device rating or setting (A)						
If Main Switch is RCD										
Rated residual operating current (ma)				Rated Time delay (ms)		N/A				
Operating time (ms)		X1		X5		ma				
Visual Inspection Satisfactory				Yes		x		No		L1=BROWN, L2=BLACK, L3=GREY
If No Give details										
Functional Testing										
Do all MCBs maually operate correctly				YES		x		NO		
If No Give details										
Do all RCD test buttons operate correctly				YES		x		NO		
If No Give details										
Do all circuit indicators operate correctly				YES		x		NO		N/A
If No Give details										
Insulation Resistance Tested at 250V due to sensitive equipment										
L1 - CPC		Mohm		Satisfactory		x		Yes		No
L2 - CPC		Mohm		Satisfactory		x		Yes		No
L3 - CPC		Mohm		Satisfactory		x		Yes		No
N-CPC		Mohm		Satisfactory		x		Yes		No
Polarity throughout Satisfactory				Yes				No		
Test Instrument serial number				1009986102219630						
Inspected By										
Name		Pierre		Zeshan						
Signature				Date		19/8/2023				



Certificate Ref: PDCERT2308190002

Schedule of Results													
Distribution Board Serial Number or ID								DB32081RCD0169					
Circuit Number	RCBO				RCD			Test results				Remarks (Continue on separate sheet if necessary)	
	Over current device												
	BS(EN)	Type (B,C,D)	Rating (A)	Breaking Capacity (KA)	BS(EN)	Rating (mA)	Time delay (ms)	RCD trip time x 1/2 (ms)	RCD trip time x 1 (ms) <300	RCD ramp test (mA)	Polarity		Test button operation
Out1		A	40	10	61008	30	0	>99			✓	✓	
1	60898	C	16	6			0	>99	25.3	21	✓	✓	
2	60898	C	16	6			0	>99	25.5	19	✓	✓	
3	60898	C	16	6			0	>99	25.3	21	✓	✓	
4	60898	C	16	6			0	>99	25.4	21	✓	✓	
5	60898	C	16	6			0	>99	25.3	21	✓	✓	
6	60898	C	16	6			0	>99	25.2	21	✓	✓	
Inspected By													
Name	Pierre		Zeshan										
Signature			Date	19/8/2023									
Test Instrument details : Serial number					Megger MFT1741 1009986102219630								

