

Certificate Ref: **PDCERT2306260002**

Portable Power Distribution Unit Test and Inspection Certification										
Distribution Board Serial Number or ID				DB325P06C163P0154						
Appliance inlet type		32		Rating (A)		1ph		3ph		X
Loop through outlet type		32		Rating (A)		1ph		3ph		X
Does the loop through output have on board protection						YES		NO		X
Main Switch / Switch Fuse/ Circuit Breaker / RCD										
BS(EN)		Not A/V		Breaking Capacity (KA)						
No of Poles				Fuse /Device rating or setting (A)						
If Main Switch is RCD										
Rated residual operating current (ma)				Rated Time delay (ms)		N/A				
Operating time (ms)		X1		X5		ma				
Visual Inspection Satisfactory				Yes		x		No		L1=BROWN, L2=BLACK, L3=GREY
If No Give details										
Functional Testing										
Do all MCBs maually operate correctly				YES		x		NO		
If No Give details										
Do all RCD test buttons operate correctly				YES		x		NO		
If No Give details										
Do all circuit indicators operate correctly				YES		x		NO		N/A
If No Give details										
Insulation Resistance Tested at 250V due to sensitive equipment										
L1 - CPC		Mohm		Satisfactory		x		Yes		No
L2 - CPC		Mohm		Satisfactory		x		Yes		No
L3 - CPC		Mohm		Satisfactory		x		Yes		No
N-CPC		Mohm		Satisfactory		x		Yes		No
Polarity throughout Satisfactory				Yes				No		
Test Instrument serial number				1009986102219630						
Inspected By										
Name		Pierre								
Signature				Date		26/6/2023				

Certificate Ref: PDCERT2306260002

Schedule of Results

Distribution Board Serial Number or ID

DB325P06C163P0154

Circuit Number	RCBO				RCD			Test results					Remarks (Continue on separate sheet if necessary)
	BS(EN)	Type (B,C,D)	Rating (A)	Breaking Capacity (KA)	BS(EN)	Rating (mA)	Time delay (ms)	RCD trip time x 1/2 (ms)	RCD trip time x 1 (ms) <300	RCD ramp test (mA)	Polarity	Test button operation	
Out1		A	40	10	61008	30	0	>99			✓	✓	
1	60898	C	16	6			0	>99	25.2	21	✓	✓	
2	60898	C	16	6			0	>99	25.1	21	✓	✓	
3	60898	C	16	6			0	>99	25	21	✓	✓	
4	60898	C	16	6			0	>99	25.1	23	✓	✓	
5	60898	C	16	6			0	>99	25.1	21	✓	✓	
6	60898	C	16	6			0	>99	24.9	21	✓	✓	

Inspected By			
Name	Pierre		
Signature		Date	26/6/2023

Test Instrument details : Serial number	Megger MFT1741 1009986102219630
--	---------------------------------