


Certificate Ref: **PDCERT2309090005**

Portable Power Distribution Unit Test and Inspection Certification										
Distribution Board Serial Number or ID				DB325P06C163P10155						
Appliance inlet type				Rating (A)		32		1ph	3ph	X
Loop through outlet type				Rating (A)				1ph	3ph	
Does the loop through output have on board protection						YES		NO		
Main Switch / Switch Fuse/ Circuit Breaker / RCD										
BS(EN)				Breaking Capacity (KA)						
No of Poles				Fuse /Device rating or setting (A)						
If Main Switch is RCD										
Rated residual operating current (ma)				Rated Time delay (ms)		N/A				
Operating time (ms)		X1		X5		ma				
Visual Inspection Satisfactory				Yes		x		No		L1=BROWN, L2=BLACK, L3=GREY
If No Give details										
Functional Testing										
Do all MCBs maually operate correctly				YES		x		NO		
If No Give details										
Do all RCD test buttons operate correctly				YES		x		NO		
If No Give details										
Do all circuit indicators operate correctly				YES		x		NO		N/A
If No Give details										
Insulation Resistance Tested at 250V due to sensitive equipment										
L1 - CPC		Mohm	Satisfactory	x	Yes			No		
L2 - CPC		Mohm	Satisfactory	x	Yes			No		
L3 - CPC		Mohm	Satisfactory	x	Yes			No		
N-CPC		Mohm	Satisfactory	x	Yes			No		
Polarity throughout Satisfactory				Yes		No				
Test Instrument serial number				1009986102219630						
Inspected By										
Name		Pierre								
Signature				Date		2023-09-09				



Certificate Ref: PDCERT2309090005

Schedule of Results

Distribution Board Serial Number or ID

DB325P06C163P10155

RCBO														
Over current device					RCD			Test results					Remarks (Continue on separate sheet if necessary)	
Circuit Number	BS(EN)	Type (B,C,D)	Rating (A)	Breaking Capacity (KA)	BS(EN)	Rating (mA)	Time delay (ms)	RCD trip time x 1/2 (ms)	RCD trip time x 1 (ms) <300	RCD ramp test (mA)	Polarity	Test button operation		
Out1		A	40	10	61008	30	0	>99			✓	✓		
1	60898	C	16	6			0	>99	28.1	21	✓	✓		
2	60898	C	16	6			0	>99	28	23	✓	✓		
3	60898	C	16	6			0	>99	28.1	23	✓	✓		
4	60898	C	16	6			0	>99	28.1	23	✓	✓		
5	60898	C	16	6			0	>99	28.2	23	✓	✓		
6	60898	C	16	6			0	>99	28	23	✓	✓		
Inspected By														
Name	Pierre													
Signature					Date	2023-09-09								
Test Instrument details : Serial number						Megger MFT1741 1009986102219630								

