


Certificate Ref: **PDCERT2307040004**


Portable Power Distribution Unit Test and Inspection Certification									
Distribution Board Serial Number or ID				DBC163P04RCD0154					
Appliance inlet type		Not A/V		Rating (A)		1ph		3ph	
Loop through outlet type		Not A/V		Rating (A)		1ph		3ph	
Does the loop through output have on board protection						YES		NO	
Main Switch / Switch Fuse/ Circuit Breaker / RCD									
BS(EN)		Not A/V		Breaking Capacity (KA)					
No of Poles				Fuse /Device rating or setting (A)					
If Main Switch is RCD									
Rated residual operating current (ma)				Rated Time delay (ms)		N/A			
Operating time (ms)		X1		X5		ma			
Visual Inspection Satisfactory				Yes		☒		No	
If No Give details									
Functional Testing									
Do all MCBs maually operate correctly				YES		☒		NO	
If No Give details									
Do all RCD test buttons operate correctly				YES		☒		NO	
If No Give details									
Do all circuit indicators operate correctly				YES		☒		NO	
If No Give details									
Insulation Resistance Tested at 250V due to sensitive equipment									
L1 - CPC		Mohm		Satisfactory		☒		Yes	
L2 - CPC		Mohm		Satisfactory		☒		Yes	
L3 - CPC		Mohm		Satisfactory		☒		Yes	
N-CPC		Mohm		Satisfactory		☒		Yes	
Polarity throughout Satisfactory				Yes		☒		No	
Test Instrument serial number				1009986102219630					
Inspected By									
Name		Pierre							
Signature				Date		2023-04-07			



Certificate Ref: PDCERT2307040004

Schedule of Results

Distribution Board Serial Number or ID	DBC163P04RCD0154
--	------------------

RCBO													
Over current device					RCD			Test results					Remarks (Continue on separate sheet if necessary)
Circuit Number	BS(EN)	Type (B,C,D)	Rating (A)	Breaking Capacity (KA)	BS(EN)	Rating (mA)	Time delay (ms)	RCD trip time x 1/2 (ms)	RCD trip time x 1 (ms) <300	RCD ramp test (mA)	Polarity	Test button operation	
Out1		A	25	6	61008	30	0	>99			✓	✓	
1	60898	C	16	6			0	>99	29.5	19	✓	✓	
Inspected By													
Name	Pierre												
Signature			Date	2023-04-07									
Test Instrument details : Serial number				Megger MFT1741 1009986102219630									

