


Certificate Ref: **PDCERT2309140002**

Portable Power Distribution Unit Test and Inspection Certification													
Distribution Board Serial Number or ID				DBC325P06T1MCBBX70152									
Appliance inlet type				Rating (A)		32		1ph		3ph		X	
Loop through outlet type				Rating (A)				1ph		3ph			
Does the loop through output have on board protection								YES				NO	
Main Switch / Switch Fuse/ Circuit Breaker / RCD													
BS(EN)		Not A/V		Breaking Capacity (KA)									
No of Poles				Fuse /Device rating or setting (A)									
If Main Switch is RCD													
Rated residual operating current (ma)								Rated Time delay (ms)		N/A			
Operating time (ms)		X1				X5				ma			
Visual Inspection Satisfactory				Yes		x		No		L1=BROWN, L2=BLACK, L3=GREY			
If No Give details													
Functional Testing													
Do all MCBs maually operate correctly				YES		x		NO					
If No Give details													
Do all RCD test buttons operate correctly				YES		x		NO					
If No Give details													
Do all circuit indicators operate correctly				YES		x		NO		N/A			
If No Give details													
Insulation Resistance Tested at 250V due to sensitive equipment													
L1 - CPC		Mohm		Satisfactory		x		Yes				No	
L2 - CPC		Mohm		Satisfactory		x		Yes				No	
L3 - CPC		Mohm		Satisfactory		x		Yes				No	
N-CPC		Mohm		Satisfactory		x		Yes				No	
Polarity throughout Satisfactory				Yes				No					
Test Instrument serial number				1009986102219630									
Inspected By													
Name		Pierre											
Signature				Date		14/9/2023							

