



Certificate Ref: **PDCERT2309020002**

Portable Power Distribution Unit Test and Inspection Certification													
Distribution Board Serial Number or ID				DBM32034RCD0152									
Appliance inlet type		C-Form		Rating (A)		32		1ph		3ph		x	
Loop through outlet type		C-Form		Rating (A)		32		1ph		3ph		x	
Does the loop through output have on board protection						YES				NO		x	
Main Switch / Switch Fuse/ Circuit Breaker / RCD													
BS(EN)		60898		Breaking Capacity (KA)		6							
No of Poles		3		Fuse /Device rating or setting (A)		32							
If Main Switch is RCD													
Rated residual operating current (ma)				Rated Time delay (ms)				N/A					
Operating time (ms)		X1		X5				ma					
Visual Inspection Satisfactory				Yes		x		No		L1=BROWN, L2=BLACK, L3=GRAY			
If No Give details													
Functional Testing													
Do all MCBs maually operate correctly				YES		x		NO					
If No Give details													
Do all RCD test buttons operate correctly				YES		x		NO					
If No Give details													
Do all circuit indicators operate correctly				YES		x		NO		N/A			
If No Give details													
Insulation Resistance Tested at 250V due to sensitive equipment													
L1 - CPC		Mohm		Satisfactory		x		Yes				No	
L2 - CPC		Mohm		Satisfactory		x		Yes				No	
L3 - CPC		Mohm		Satisfactory		x		Yes				No	
N-CPC		Mohm		Satisfactory		x		Yes				No	
Polarity throughout Satisfactory				Yes				No					
Test Instrument serial number				1009986102219630									
Inspected By													
Name		Pierre											
Signature				Date		2023-02-09							



Certificate Ref: PDCERT2309020002

Schedule of Results													
Distribution Board Serial Number or ID								S/N DBM32034RCD0152					
Circuit Number	RCBO				RCD			Test results				Remarks (Continue on separate sheet if necessary)	
	BS(EN)	Type (B,C,D)	Rating (A)	Breaking Capacity (KA)	BS(EN)	Rating (mA)	Time delay (ms)	RCD trip time x 1/2 (ms)	RCD trip time x 1 (ms) <300	RCD ramp test (mA)	Polarity		Test button operation
Out1		A	40	10	61008	30	0	>99			✓	✓	
1	60898	C	16	6			0	>99	25.6	21	✓	✓	
2	60898	C	16	6			0	>99	25.6	21	✓	✓	
3	60898	C	16	6			0	>99	25.4	21	✓	✓	
1	60898	C	16	6			0	>99	25.7	23	✓	✓	
2	60898	C	16	6			0	>99	25.7	21	✓	✓	
3	60898	C	16	6			0	>99	25.5	23	✓	✓	
1	60898	C	16	6			0	>99	25.8	23	✓	✓	
2	60898	C	16	6			0	>99	25.7	21	✓	✓	
3	60898	C	16	6			0	>99	25.4	21	✓	✓	

Inspected By			
Name	Pierre		
Signature		Date	2023-02-09
Test Instrument details : Serial number		Megger MFT1741 1009986102219630	

