

Certificate Ref: **PDCERT2312300007**

Portable Power Distribution Unit Test and Inspection Certification										
Distribution Board Serial Number or ID				DBM32090RCD0221						
Appliance inlet type		C-Form		Rating (A)		32		1ph	3ph	x
Loop through outlet type				Rating (A)				1ph	3ph	
Does the loop through output have on board protection						YES		NO		
Main Switch / Switch Fuse/ Circuit Breaker / RCD										
BS(EN)		60898		Breaking Capacity (KA)		6				
No of Poles		4		Fuse /Device rating or setting (A)		32				
If Main Switch is RCD										
Rated residual operating current (ma)				Rated Time delay (ms)		N/A				
Operating time (ms)		X1		X5		ma				
Visual Inspection Satisfactory				Yes		x		No		L1=BROWN, L2=BLACK, L3=GRAY
If No Give details										
Functional Testing										
Do all MCBs maually operate correctly				YES		x		NO		
If No Give details										
Do all RCD test buttons operate correctly				YES		x		NO		
If No Give details										
Do all circuit indicators operate correctly				YES		x		NO		N/A
If No Give details										
Insulation Resistance Tested at 250V due to sensitive equipment										
L1 - CPC		Mohm		Satisfactory		Yes		No		
L2 - CPC		Mohm		Satisfactory		Yes		No		
L3 - CPC		Mohm		Satisfactory		Yes		No		
N-CPC		Mohm		Satisfactory		Yes		No		
Polarity throughout Satisfactory				Yes		No				
Test Instrument serial number				1009986102219630						
Inspected By										
Name		Maroun		Date		30/12/2023				
Signature										

Certificate Ref: PDCERT2312300007

Schedule of Results


Distribution Board Serial Number or ID	S/N DBM32090RCD0221
--	---------------------

	RCBO							Test results					Remarks (Continue on separate sheet if necessary)
	Over current device				RCD								
Circuit Number	BS(EN)	Type (B,C,D)	Rating (A)	Breaking Capacity (kA)	BS(EN)	Rating (mA)	Time delay (ms)	RCD trip time x 1/2 (ms)	RCD trip time x 1 (ms) <300	RCD ramp test (mA)	Polarity	Test button operation	
Out1		A	40	10	61008	30	0	>99			✓	✓	
1	60898	C	16	6			0	>99	24.7	19	✓	✓	
2	60898	C	16	6			0	>99	24.8	19	✓	✓	
3	60898	C	16	6			0	>99	24.9	19	✓	✓	
4	60898	C	16	6			0	>99	24.6	19	✓	✓	
5	60898	C	16	6			0	>99	24.7	19	✓	✓	
6	60898	C	16	6			0	>99	25	21	✓	✓	
7	60898	C	32	6			0	>99	24.2	19	✓	✓	
8	60898	C	32	6			0	>99	24.7	21	✓	✓	
9	60898	C	32	6			0	>99	24.9	19	✓	✓	

ماور ديتروستور للالكترونيات ش.م.ذ.م.ج

P.O. Box: 35428
Dubai - U.A.E.

POWER DISTROS MANUFACTURERS



Inspected By			
Name	Maroun		
Signature		Date	30/12/2023



Test Instrument details : Serial number	Megger MFT1741 1009986102219630
---	---------------------------------