


Certificate Ref: **PDCERT2309230007**


Portable Power Distribution Unit Test and Inspection Certification									
Distribution Board Serial Number or ID				DBR32095RCBO0158					
Appliance inlet type		C-Form		Rating (A)		32		1ph	
Loop through outlet type		C-Form		Rating (A)		32		1ph	
Does the loop through output have on board protection				YES				NO	
Main Switch / Switch Fuse/ Circuit Breaker / RCD									
BS(EN)		60898		Breaking Capacity (KA)		6			
No of Poles		4		Fuse /Device rating or setting (A)		32			
If Main Switch is RCD									
Rated residual operating current (ma)				Rated Time delay (ms)		N/A			
Operating time (ms)		X1		X5				ma	
Visual Inspection Satisfactory				Yes		x		No	
If No Give details									
Functional Testing									
Do all MCBs maually operate correctly				YES		x		NO	
If No Give details									
Do all RCD test buttons operate correctly				YES		x		NO	
If No Give details									
Do all circuit indicators operate correctly				YES		x		NO	
If No Give details									
Insulation Resistance Tested at 250V due to sensitive equipment									
L1 - CPC		Mohm		Satisfactory		x		Yes	
L2 - CPC		Mohm		Satisfactory		x		Yes	
L3 - CPC		Mohm		Satisfactory		x		Yes	
N-CPC		Mohm		Satisfactory		x		Yes	
Polarity throughout Satisfactory				Yes				No	
Test Instrument serial number				1009986102219630					
Inspected By				1009986102219630 Dubai - U.A.E.					
Name		Pierre		Nawazish					
Signature				Date		23/9/2023			

Certificate Ref: PDCERT2309230007

Schedule of Results

Distribution Board Serial Number or ID

DBM32095RCBO0158

RCBO														
Over current device					RCD			Test results					Remarks (Continue on separate sheet if necessary)	
Circuit Number	BS(EN)	Type (B,C,D)	Rating (A)	Breaking Capacity (KA)	BS(EN)	Rating (mA)	Time delay (ms)	RCD trip time x 1/2 (ms)	RCD trip time x 1 (ms) <300	RCD ramp test (mA)	Polarity	Test button operation		
OUT														
1	61009	C	16	6	61009	30	0	>99	23.4	19	✓	✓		
2	61009	C	16	6	61009	30	0	>99	23.6	21	✓	✓		
3	61009	C	16	6	61009	30	0	>99	23.5	21	✓	✓		
4	61009	C	16	6	61009	30	0	>99	23.5	19	✓	✓		
5	61009	C	16	6	61009	30	0	>99	23.5	19	✓	✓		
6	61009	C	16	6	61009	30	0	>99	23.4	19	✓	✓		
7	61009	C	16	6	61009	30	0	>99	23.5	19	✓	✓		
8	61009	C	16	6	61009	30	0	>99	23.5	19	✓	✓		
9	61009	C	16	6	61009	30	0	>99	23.5	19	✓	✓		
Inspected By														
Name	Pierre			Nawazish										
Signature				Date	23/9/2023									
Test Instrument details : Serial number					Megger MFT1741 1009986102219630									

