


Certificate Ref: **PDCERT2309110002**

Portable Power Distribution Unit Test and Inspection Certification									
Distribution Board Serial Number or ID				DBM63184RCD0153					
Appliance inlet type		C-FORM		Rating (A)		63		1ph	
Loop through outlet type				Rating (A)				1ph	
Does the loop through output have on board protection						YES		NO	
Main Switch / Switch Fuse/ Circuit Breaker / RCD									
BS(EN)		60898		Breaking Capacity (KA)		6			
No of Poles		3		Fuse /Device rating or setting (A)		63			
If Main Switch is RCD									
Rated residual operating current (ma)				Rated Time delay (ms)		N/A			
Operating time (ms)		X1		X5		ma			
Visual Inspection Satisfactory				Yes		x		No	
If No Give details									
Functional Testing									
Do all MCBs maually operate correctly				YES		x		NO	
If No Give details									
Do all RCD test buttons operate correctly				YES		x		NO	
If No Give details									
Do all circuit indicators operate correctly				YES		x		NO	
If No Give details									
Insulation Resistance Tested at 250V due to sensitive equipment									
L1 - CPC		Mohm		Satisfactory		x		Yes	
L2 - CPC		Mohm		Satisfactory		x		Yes	
L3 - CPC		Mohm		Satisfactory		x		Yes	
N-CPC		Mohm		Satisfactory		x		Yes	
Polarity throughout Satisfactory				Yes		x		No	
Test Instrument serial number				1009986102219630					
Inspected By									
Name		Pierre		Zeshan					
Signature				Date		2023-11-09			

Certificate Ref: PDCERT2309110002

Schedule of Results													
Distribution Board Serial Number or ID								DBM63184RCD0154					
Circuit Number	RCBO				RCD			Test results				Remarks (Continue on separate sheet if necessary)	
	BS(EN)	Type (B,C,D)	Rating (A)	Breaking Capacity (KA)	BS(EN)	Rating (mA)	Time delay (ms)	RCD trip time x 1/2 (ms)	RCD trip time x 1 (ms) <300	RCD ramp test (mA)	Polarity		Test button operation
Out1		A	40	10	61008	30	0	>99			✓	✓	
1	60898	C	16	6			0	>99	28.6	19	✓	✓	
2	60898	C	16	6			0	>99	28.4	19	✓	✓	
3	60898	C	16	6			0	>99	28.2	21	✓	✓	
4	60898	C	16	6			0	>99	28.4	21	✓	✓	
5	60898	C	16	6			0	>99	28.4	21	✓	✓	
6	60898	C	16	6			0	>99	29.4	19	✓	✓	
Out2		A	40	10	61008	30	0	>99			✓	✓	
1	60898	C	16	6			0	>99	28.6	21	✓	✓	
2	60898	C	16	6			0	>99	28.8	25	✓	✓	
3	60898	C	16	6			0	>99	28.7	21	✓	✓	
4	60898	C	16	6			0	>99	28.7	21	✓	✓	
5	60898	C	16	6			0	>99	28.7	21	✓	✓	
6	60898	C	16	6			0	>99	28.7	21	✓	✓	
Out3		A	40	10	61008	30	0	>99			✓	✓	
1	60898	C	32	6			0	>99	25.3	21	✓	✓	
2	60898	C	32	6			0	>99	25.2	21	✓	✓	
3	60898	C	32	6			0	>99	25.3	23	✓	✓	
Inspected By													
Name	Pierre				Zeshan								
Signature					Date				2023-11-09				
Test Instrument details : Serial number								Megger MFT1741 1009986102219630					

