





Certificate Ref: **PDCERT2306060002**

Portable Power Distribution Unit Test and Inspection Certification									
Distribution Board Serial Number or ID				DBM63391RCD0152					
Appliance inlet type		C-Form		Rating (A)		63		1ph	
Loop through outlet type		C-Form		Rating (A)		63		1ph	
Does the loop through output have on board protection				YES		NO		X	
Main Switch / Switch Fuse/ Circuit Breaker / RCD									
BS(EN)		60898		Breaking Capacity (KA)		6			
No of Poles		3		Fuse /Device rating or setting (A)		63			
If Main Switch is RCD									
Rated residual operating current (ma)				Rated Time delay (ms)		N/A			
Operating time (ms)		X1		X5		ma			
Visual Inspection Satisfactory				Yes		X		No	
If No Give details									
Functional Testing									
Do all MCBs maually operate correctly				YES		X		NO	
If No Give details									
Do all RCD test buttons operate correctly				YES		X		NO	
If No Give details									
Do all circuit indicators operate correctly				YES		X		NO	
If No Give details									
Insulation Resistance Tested at 250V due to sensitive equipment									
L1 - CPC		1.8 Mohm		Satisfactory		X		Yes	
L2 - CPC		2.2 Mohm		Satisfactory		X		Yes	
L3 - CPC		2.7 Mohm		Satisfactory		X		Yes	
N-CPC		1.9 Mohm		Satisfactory		X		Yes	
Polarity throughout Satisfactory				Yes		No			
Test Instrument serial number				1009986102219630					
Inspected By				Pierre					
Name		Pierre		Date		2023-06-06			
Signature									



Certificate Ref: PDCERT2306060002

Schedule of Results																																																																					
Distribution Board Serial Number or ID								S/N DBM63391RCD0152																																																													
RCBO																																																																					
Over current device					RCD			Test results				Remarks (Continue on separate sheet if necessary)																																																									
Circuit Number	BS(EN)	Type (B,C,D)	Rating (A)	Breaking Capacity (KA)	BS(EN)	Rating (mA)	Time delay (ms)	RCD trip time x 1/2 (ms)	RCD trip time x 1 (ms) <300	RCD ramp test (mA)	Polarity			Test button operation																																																							
Out1		A	40	10	61008	30	0	>99			✓	✓																																																									
1	60898	C	32	6			0	>99	28.4	19	✓	✓																																																									
2	60898	C	32	6			0	>99	28.5	19	✓	✓																																																									
3	60898	C	32	6			0	>99	28.5	21	✓	✓																																																									
Out2		A	40	10	61008	30	0	>99			✓	✓																																																									
1	60898	C	32	6			0	>99	25.2	21	✓	✓																																																									
2	60898	C	32	6			0	>99	25.2	21	✓	✓																																																									
3	60898	C	32	6			0	>99	25.2	23	✓	✓																																																									
																																																																					
<table border="1"> <tr> <td colspan="2">Inspected By</td> <td colspan="12"></td> </tr> <tr> <td>Name</td> <td colspan="2">Pierre</td> <td colspan="11"></td> </tr> <tr> <td>Signature</td> <td colspan="2"></td> <td>Date</td> <td colspan="10">2023-06-06</td> </tr> <tr> <td colspan="4">Test Instrument details : Serial number</td> <td colspan="10">Megger MFT1741 1009986102219630</td> </tr> </table>														Inspected By														Name	Pierre													Signature			Date	2023-06-06										Test Instrument details : Serial number				Megger MFT1741 1009986102219630									
Inspected By																																																																					
Name	Pierre																																																																				
Signature			Date	2023-06-06																																																																	
Test Instrument details : Serial number				Megger MFT1741 1009986102219630																																																																	