

Certificate Ref: **PDCERT2309090009**

Portable Power Distribution Unit Test and Inspection Certification										
Distribution Board Serial Number or ID				DBM63595MCCB0151						
Appliance inlet type		C-Form		Rating (A)		63		1ph	3ph	x
Loop through outlet type				Rating (A)				1ph	3ph	
Does the loop through output have on board protection						YES		NO		
Main Switch / Switch Fuse/ Circuit Breaker / RCD										
BS(EN)		60898		Breaking Capacity (KA)		6				
No of Poles		3		Fuse /Device rating or setting (A)		63				
If Main Switch is RCD										
Rated residual operating current (ma)				Rated Time delay (ms)		N/A				
Operating time (ms)		X1		X5		ma				
Visual Inspection Satisfactory				Yes		x		No		L1=BROWN, L2=BLACK, L3=GRAY
If No Give details										
Functional Testing										
Do all MCBs maually operate correctly				YES		x		NO		
If No Give details										
Do all RCD test buttons operate correctly				YES		x		NO		
If No Give details										
Do all circuit indicators operate correctly				YES		x		NO		N/A
If No Give details										
Insulation Resistance Tested at 250V due to sensitive equipment										
L1 - CPC		Mohm		Satisfactory		x		Yes		No
L2 - CPC		Mohm		Satisfactory		x		Yes		No
L3 - CPC		Mohm		Satisfactory		x		Yes		No
N-CPC		Mohm		Satisfactory		x		Yes		No
Polarity throughout Satisfactory				Yes		No				
Test Instrument serial number				1009986102219630						
Inspected By										
Name		Pierre		Date		2023-09-09				
Signature										