


Certificate Ref: **PDCERT2306220002**

Portable Power Distribution Unit Test and Inspection Certification									
Distribution Board Serial Number or ID				MD125010RCBO0153					
Appliance inlet type		C-Form		Rating (A)		125		1ph	
Loop through outlet type		C-Form		Rating (A)		125		1ph	
Does the loop through output have on board protection				YES				NO	
Main Switch / Switch Fuse/ Circuit Breaker / RCD									
BS(EN)		60898		Breaking Capacity (KA)		16			
No of Poles		4		Fuse /Device rating or setting (A)		125			
If Main Switch is RCD									
Rated residual operating current (ma)				Rated Time delay (ms)		N/A			
Operating time (ms)		X1		X5				ma	
Visual Inspection Satisfactory				Yes		x		No	
If No Give details									
Functional Testing									
Do all MCBs maually operate correctly				YES		x		NO	
If No Give details									
Do all RCD test buttons operate correctly				YES		x		NO	
If No Give details									
Do all circuit indicators operate correctly				YES		x		NO	
If No Give details									
Insulation Resistance Tested at 250V due to sensitive equipment									
L1 - CPC		1.6 Mohm		Satisfactory		x		Yes	
L2 - CPC		2.6 Mohm		Satisfactory		x		Yes	
L3 - CPC		2.55 Mohm		Satisfactory		x		Yes	
N-CPC		1.9 Mohm		Satisfactory		x		Yes	
Polarity throughout Satisfactory				Yes				No	
Test Instrument serial number				1009986102219630					
Inspected By									
Name		Pierre		Umar					
Signature				Date		22/6/2023			

Certificate Ref: PDCERT2306220002


Schedule of Results

Distribution Board Serial Number or ID

MD125010RCBO0153

	RCBO							Test results					Remarks (Continue on separate sheet if necessary)
	Over current device				RCD								
Circuit Number	BS(EN)	Type (B,C,D)	Rating (A)	Breaking Capacity (KA)	BS(EN)	Rating (mA)	Time delay (ms)	RCD trip time x 1/2 (ms)	RCD trip time x 1 (ms) <300	RCD ramp test (mA)	Polarity	Test button operation	
Out1	61009	C	16	6	61009	30	0	>99	23.6	19	✓	✓	
Out2	61009	C	16	6	61009	30	0	>99	23.5	19	✓	✓	
Out3	61009	C	16	6	61009	30	0	>99	23.6	19	✓	✓	
Out4	61009	C	16	6	61009	30	0	>99	23.6	19	✓	✓	
Out5	61009	C	16	6	61009	30	0	>99	23.5	19	✓	✓	
Out6	61009	C	16	6	61009	30	0	>99	23.7	19	✓	✓	
Out7													
1	61009	C	16	6	61009	30	0	>99	23.4	19	✓	✓	
2	61009	C	16	6	61009	30	0	>99	24.1	21	✓	✓	
3	61009	C	16	6	61009	30	0	>99	23.9	19	✓	✓	
4	61009	C	16	6	61009	30	0	>99	23.4	19	✓	✓	
5	61009	C	16	6	61009	30	0	>99	23.7	19	✓	✓	
6	61009	C	16	6	61009	30	0	>99	23.5	19	✓	✓	
Out8													
1	61009	C	16	6	61009	30	0	>99	23.9	19	✓	✓	
2	61009	C	16	6	61009	30	0	>99	23.3	19	✓	✓	
3	61009	C	16	6	61009	30	0	>99	23.4	19	✓	✓	
4	61009	C	16	6	61009	30	0	>99	23.9	19	✓	✓	
5	61009	C	16	6	61009	30	0	>99	23.3	19	✓	✓	
6	61009	C	16	6	61009	30	0	>99	23.8	19	✓	✓	



Out9														
1	61009	C	16	6	61009	30	0	>99	23.3	19	✓	✓		
2	61009	C	16	6	61009	30	0	>99	23.5	19	✓	✓		
3	61009	C	16	6	61009	30	0	>99	23.8	19	✓	✓		
4	61009	C	16	6	61009	30	0	>99	23.5	19	✓	✓		
5	61009	C	16	6	61009	30	0	>99	23.5	19	✓	✓		
6	61009	C	16	6	61009	30	0	>99	23.6	19	✓	✓		
Out10														
1	61009	C	16	6	61009	30	0	>99	23.3	19	✓	✓		
2	61009	C	16	6	61009	30	0	>99	23.4	19	✓	✓		
3	61009	C	16	6	61009	30	0	>99	23.3	19	✓	✓		
4	61009	C	16	6	61009	30	0	>99	23.4	19	✓	✓		
5	61009	C	16	6	61009	30	0	>99	23.3	19	✓	✓		
6	61009	C	16	6	61009	30	0	>99	23.4	19	✓	✓		
Out11		A	63	10	61008	30	0	>99			✓	✓		
1	60898	C	63	6			0	>99	29.2	25	✓	✓		
2	60898	C	63	6			0	>99	29.2	21	✓	✓		
3	60898	C	63	6			0	>99	29.2	23	✓	✓		
Out12		A	40	10	61008	30	0	>99			✓	✓		
1	60898	C	32	6			0	>99	28.7	21	✓	✓		
2	60898	C	32	6			0	>99	28.7	21	✓	✓		
3	60898	C	32	6			0	>99	28.6	21	✓	✓		
AUX	60898	C	10	6			0	>99	9	21	✓	✓		
Inspected By														
Name	Pierre			Umair										
Signature				Date	22/6/2023									
Test Instrument details : Serial number					Megger MFT1741 1009986102219630									