


Certificate Ref: **PDCERT2307110002**

Portable Power Distribution Unit Test and Inspection Certification									
Distribution Board Serial Number or ID				MD125034RCBO0153					
Appliance inlet type		C-Form		Rating (A)		125		1ph	
Loop through outlet type		C-Form		Rating (A)		125		1ph	
Does the loop through output have on board protection				YES				NO	
Main Switch / Switch Fuse/ Circuit Breaker / RCD									
BS(EN)		60898		Breaking Capacity (KA)		16			
No of Poles		4		Fuse /Device rating or setting (A)		125			
If Main Switch is RCD									
Rated residual operating current (ma)				Rated Time delay (ms)		N/A			
Operating time (ms)		X1		X5				ma	
Visual Inspection Satisfactory				Yes		x		No	
If No Give details									
Functional Testing									
Do all MCBs maually operate correctly				YES		x		NO	
If No Give details									
Do all RCD test buttons operate correctly				YES		x		NO	
If No Give details									
Do all circuit indicators operate correctly				YES		x		NO	
If No Give details									
Insulation Resistance Tested at 250V due to sensitive equipment									
L1 - CPC		2.5 Mohm		Satisfactory		x		Yes	
L2 - CPC		2.6 Mohm		Satisfactory		x		Yes	
L3 - CPC		2.55 Mohm		Satisfactory		x		Yes	
N-CPC		1.9 Mohm		Satisfactory		x		Yes	
Polarity throughout Satisfactory				Yes				No	
Test Instrument serial number				1009986102219630					
Inspected By									
Name		Pierre		Umar					
Signature				Date		2023-11-07			

Certificate Ref: PDCERT2307110002

Schedule of Results


Distribution Board Serial Number or ID

MD125034RCBO0153

	RCBO												
	Over current device				RCD			Test results					
Circuit Number	BS(EN)	Type (B,C,D)	Rating (A)	Breaking Capacity (KA)	BS(EN)	Rating (mA)	Time delay (ms)	RCD trip time x 1/2 (ms)	RCD trip time x 1 (ms) <300	RCD ramp test (mA)	Polarity	Test button operation	Remarks (Continue on separate sheet if necessary)
Out1	61009	C	16	6	61009	30	0	>99	23.6	19	✓	✓	
Out2	61009	C	16	6	61009	30	0	>99	23.4	19	✓	✓	
Out3	61009	C	16	6	61009	30	0	>99	23.3	19	✓	✓	
Out4	61009	C	10	6	61009	30	0	>99	8.9	21	✓	✓	
Out5	61009	C	10	6	61009	30	0	>99	8.8	19	✓	✓	
Out6	61009	C	10	6	61009	30	0	>99	9	21	✓	✓	
Out7		A	40	10	61008	30	0	>99			✓	✓	
1	60898	C	32	6			0	>99	28.9	21	✓	✓	
2	60898	C	32	6			0	>99	28.8	23	✓	✓	
3	60898	C	32	6			0	>99	28.8	23	✓	✓	
Out8		A	40	10	61008	30	0	>99			✓	✓	
1	60898	C	32	6			0	>99	28.8	23	✓	✓	
2	60898	C	32	6			0	>99	28.7	21	✓	✓	
3	60898	C	32	6			0	>99	28.6	23	✓	✓	





Out9		A	40	10	61008	30	0	>99			✓	✓	
1	60898	C	32	6			0	>99	28.8	21	✓	✓	
2	60898	C	32	6			0	>99	28.7	19	✓	✓	
3	60898	C	32	6			0	>99	28.8	21	✓	✓	
Out10		A	40	10	61008	30	0	>99			✓	✓	
1	60898	C	32	6			0	>99	28.6	19	✓	✓	
2	60898	C	32	6			0	>99	28.8	21	✓	✓	
3	60898	C	32	6			0	>99	28.8	21	✓	✓	
Out11		A	63	10	61008	30	0	>99			✓	✓	
1	60898	C	63	6			0	>99	25.3	21	✓	✓	
2	60898	C	63	6			0	>99	25.6	21	✓	✓	
3	60898	C	63	6			0	>99	25.9	21	✓	✓	
Inspected By													
Name	Pierre		Umail										
Signature			Date	2023-11-07									
Test Instrument details : Serial number						Megger MFT1741 1009986102219630							