


Certificate Ref: **PDCERT2306090001**

Portable Power Distribution Unit Test and Inspection Certification									
Distribution Board Serial Number or ID				MD125215RCD0151					
Appliance inlet type		C-Form		Rating (A)	125	1ph		3ph	x
Loop through outlet type		C-Form		Rating (A)	125	1ph		3ph	x
Does the loop through output have on board protection					YES		NO		x
Main Switch / Switch Fuse/ Circuit Breaker / RCD									
BS(EN)		60898		Breaking Capacity (KA)		16			
No of Poles		4		Fuse /Device rating or setting (A)		125			
If Main Switch is RCD									
Rated residual operating current (ma)				Rated Time delay (ms)		N/A			
Operating time (ms)		X1		X5				ma	
Visual Inspection Satisfactory				Yes	x	No	L1=Brown L2=Black L3=Gray		
If No Give details									
Functional Testing									
Do all MCBs maually operate correctly				YES	x	NO			
If No Give details									
Do all RCD test buttons operate correctly				YES	x	NO			
If No Give details									
Do all circuit indicators operate correctly				YES	x	NO		N/A	
If No Give details									
Insulation Resistance Tested at 250V due to sensitive equipment									
L1 - CPC	2	Mohm	Satisfactory	x	Yes		No		
L2 - CPC	2.2	Mohm	Satisfactory	x	Yes		No		
L3 - CPC	2.5	Mohm	Satisfactory	x	Yes		No		
N-CPC	1.9	Mohm	Satisfactory	x	Yes		No		
Polarity throughout Satisfactory				Yes		No			
Test Instrument serial number				1009986102219630					
Inspected By									
Name		Pierre		Zeshan					
Signature				Date		2023-09-06			

Certificate Ref: PDCERT2306090001

Schedule of Results													
Distribution Board Serial Number or ID								MD125215RCD0151					
Circuit Number	RCBO							Test results					Remarks (Continue on separate sheet if necessary)
	Over current device				RCD								
	BS(EN)	Type (B,C,D)	Rating (A)	Breaking Capacity (kA)	BS(EN)	Rating (mA)	Time delay (ms)	RCD trip time x 1/2 (ms)	RCD trip time x 1 (ms) <300	RCD ramp test (mA)	Polarity	Test button operation	
Out1		A	40	10	61008	30	0	>99			✓	✓	
1	60898	C	16	6			0	>99	17.2	19	✓	✓	
2	60898	C	16	6			0	>99	16.5	19	✓	✓	
3	60898	C	16	6			0	>99	16.4	19	✓	✓	
4	60898	C	16	6			0	>99	16.6	19	✓	✓	
5	60898	C	16	6			0	>99	16.4	19	✓	✓	
6	60898	C	16	6			0	>99	15.9	19	✓	✓	
Out2		A	40	10	61008	30	0	>99			✓	✓	
1	60898	C	16	6			0	>99	29.1	21	✓	✓	
2	60898	C	16	6			0	>99	29	21	✓	✓	
3	60898	C	16	6			0	>99	28	21	✓	✓	
4	60898	C	16	6			0	>99	29	21	✓	✓	
5	60898	C	16	6			0	>99	29	21	✓	✓	
6	60898	C	16	6			0	>99	28.9	21	✓	✓	
Out3		A	40	10	61008	30	0	>99			✓	✓	
1	60898	C	32	6			0	>99	25.3	21	✓	✓	
2	60898	C	32	6			0	>99	25.4	21	✓	✓	
3	60898	C	32	6			0	>99	25.3	21	✓	✓	
Out4		A	40	10	61008	30	0	>99			✓	✓	
1	60898	C	32	6			0	>99	29.3	25	✓	✓	
2	60898	C	32	6			0	>99	29	23	✓	✓	
3	60898	C	32	6			0	>99	29.3	21	✓	✓	
Out5		A	40	10	61008	30	0	>99			✓	✓	
1	60898	C	32	6			0	>99	25.7	21	✓	✓	
2	60898	C	32	6			0	>99	25.7	21	✓	✓	
3	60898	C	32	6			0	>99	25.5	21	✓	✓	
Out6		A	40	10	61008	30	0	>99			✓	✓	
1	60898	C	32	6			0	>99	26	23	✓	✓	
2	60898	C	32	6			0	>99	25.8	25	✓	✓	
3	60898	C	32	6			0	>99	25.8	25	✓	✓	
Out7		A	63	10	61008	30	0	>99			✓	✓	
1	60898	C	63	6			0	>99	28.4	23	✓	✓	
2	60898	C	63	6			0	>99	28.3	21	✓	✓	
3	60898	C	63	6			0	>99	28.3	23	✓	✓	
Inspected By													
Name	Pierre				Zeshan								
Signature					Date				2023-09-06				
Test Instrument details : Serial number								Megger MFT1741 1009986102219630					