

Certificate Ref:PDCERT2312300010

Portable Power Distribution Unit Test and Inspection Certification									
Distribution Board Serial Number or ID				MD250391RCD0157					
Appliance inlet type		C-FORM		Rating (A)		125		1ph	
Loop through outlet type		C-FORM		Rating (A)		125		1ph	
Does the loop through output have on board protection				YES		x		NO	
Main Switch / Switch Fuse/ Circuit Breaker / RCD									
BS(EN)		60898		Breaking Capacity (KA)		16			
No of Poles		4		Fuse /Device rating or setting (A)		125			
If Main Switch is RCD									
Rated residual operating current (ma)				Rated Time delay (ms)		N/A			
Operating time (ms)		X1		X5		ma			
Visual Inspection Satisfactory				Yes		x		No	
If No Give details									
Functional Testing									
Do all MCBs maually operate correctly				Yes		x		No	
If No Give details									
Do all RCD test buttons operate correctly				Yes		x		No	
If No Give details									
Do all circuit indicators operate correctly				Yes		x		No	
If No Give details									
Insulation Resistance Tested at 250V due to sensitive equipment									
L1 - CPC		Mohm		Satisfactory		x		Yes	
L2 - CPC		Mohm		Satisfactory		x		Yes	
L3 - CPC		Mohm		Satisfactory		x		Yes	
N-CPC		Mohm		Satisfactory		x		Yes	
Polarity throughout Satisfactory				Yes		x		No	
Test Instrument serial number				1009986102219630					
Inspected By									
Name		Maroun							
Signature				Date		30/12/2023			

Schedule of Results		
Distribution Board Serial Number or ID	MD250391RCD0157	

Inspected By				
Name	Maroun			
Signature	Date	30/12/2023		
Test Instrument details : Serial number			Megger MFT1741 1009986102219630	