



Certificate Ref: **PDCERT2309180001**

Portable Power Distribution Unit Test and Inspection Certification									
Distribution Board Serial Number or ID				MD400230RCBO0151					
Appliance inlet type		PowerLock		Rating (A)		400		1ph	
Loop through outlet type		PowerLock		Rating (A)		400		1ph	
Does the loop through output have on board protection				YES				NO	
Main Switch / Switch Fuse/ Circuit Breaker / RCD									
BS(EN)		60947		Breaking Capacity (KA)		18			
No of Poles		4		Fuse /Device rating or setting (A)		400			
If Main Switch is RCD									
Rated residual operating current (ma)				Rated Time delay (ms)		N/A			
Operating time (ms)		X1		X5				ma	
Visual Inspection Satisfactory				Yes		x		No	
If No Give details				L1=Brown L2=Black L3=Gray					
Functional Testing									
Do all MCBs maually operate correctly				YES		x		NO	
If No Give details									
Do all RCD test buttons operate correctly				YES		x		NO	
If No Give details									
Do all circuit indicators operate correctly				YES		x		NO	
If No Give details				N/A					
Insulation Resistance Tested at 250V due to sensitive equipment									
L1 - CPC		Mohm		Satisfactory		x		Yes	
L2 - CPC		Mohm		Satisfactory		x		Yes	
L3 - CPC		Mohm		Satisfactory		x		Yes	
N-CPC		Mohm		Satisfactory		x		Yes	
Polarity throughout Satisfactory				Yes				No	
Test Instrument serial number				1009986102219630					
Inspected By				Nawazish					
Name		Pierre		Date		18/9/2023			
Signature									

Certificate Ref:PCERT2309180001

Schedule of Results														
Distribution Board Serial Number or ID								MD400230RCBO0151						
Circuit Number	RCBO							Test results						Remarks (Continue on separate sheet if necessary)
	Over current device				RCD									
	BS(EN)	Type (B,C,D)	Rating (A)	Breaking Capacity (kA)	BS(EN)	Rating (mA)	Time delay (ms)	RCD trip time x 1/2 (ms)	RCD trip time x 1 (ms) <300	RCD ramp test (mA)	Polarity	Test button operation		
Out1														
1	61009	C	10	6	61009	30	0	>99	23	19	✓	✓		
2	61009	C	10	6	61009	30	0	>99	22.9	19	✓	✓		
3	61009	C	10	6	61009	30	0	>99	23.7	21	✓	✓		
4	61009	C	10	6	61009	30	0	>99	23.3	21	✓	✓		
5	61009	C	10	6	61009	30	0	>99	23.1	19	✓	✓		
6	61009	C	10	6	61009	30	0	>99	23.2	19	✓	✓		
Out2														
1	61009	C	16	6	61009	30	0	>99	23.2	19	✓	✓		
2	61009	C	16	6	61009	30	0	>99	23.8	21	✓	✓		
3	61009	C	16	6	61009	30	0	>99	23.3	19	✓	✓		
4	61009	C	16	6	61009	30	0	>99	23.5	19	✓	✓		
5	61009	C	16	6	61009	30	0	>99	23.2	19	✓	✓		
6	61009	C	16	6	61009	30	0	>99	23.8	21	✓	✓		
Out3								>99			✓	✓		
1	61009	C	16	6	61009	30	0	>99	22.9	17	✓	✓		
2	61009	C	16	6	61009	30	0	>99	24	21	✓	✓		
3	61009	C	16	6	61009	30	0	>99	23.9	21	✓	✓		
4	61009	C	16	6	61009	30	0	>99	23.6	19	✓	✓		
5	61009	C	16	6	61009	30	0	>99	22.9	19	✓	✓		
6	61009	C	16	6	61009	30	0	>99	23.4	19	✓	✓		

Out4														
1	61009	C	16	6	61009	30	0	>99	23.3	19	✓	✓		
2	61009	C	16	6	61009	30	0	>99	23.3	19	✓	✓		
3	61009	C	16	6	61009	30	0	>99	23.5	21	✓	✓		
4	61009	C	16	6	61009	30	0	>99	23.5	21	✓	✓		
5	61009	C	16	6	61009	30	0	>99	23	17	✓	✓		
6	61009	C	16	6	61009	30	0	>99	23.4	21	✓	✓		
Out5														
1	61009	C	16	6	61009	30	0	>99	23	19	✓	✓		
2	61009	C	16	6	61009	30	0	>99	23.3	21	✓	✓		
3	61009	C	16	6	61009	30	0	>99	23.5	19	✓	✓		
4	61009	C	16	6	61009	30	0	>99	23.6	21	✓	✓		
5	61009	C	16	6	61009	30	0	>99	23.5	19	✓	✓		
6	61009	C	16	6	61009	30	0	>99	23.5	19	✓	✓		
Out6														
1	61009	C	16	6	61009	30	0	>99	23.2	19	✓	✓		
2	61009	C	16	6	61009	30	0	>99	23.4	19	✓	✓		
3	61009	C	16	6	61009	30	0	>99	23.2	19	✓	✓		
4	61009	C	16	6	61009	30	0	>99	23	19	✓	✓		
5	61009	C	16	6	61009	30	0	>99	23	19	✓	✓		
6	61009	C	16	6	61009	30	0	>99	23.3	23	✓	✓		
Out7														
1	61009	C	16	6	61009	30	0	>99	23	19	✓	✓		
2	61009	C	16	6	61009	30	0	>99	23	17	✓	✓		
3	61009	C	16	6	61009	30	0	>99	23.2	19	✓	✓		
4	61009	C	16	6	61009	30	0	>99	23.3	19	✓	✓		
5	61009	C	16	6	61009	30	0	>99	23.1	19	✓	✓		
6	61009	C	16	6	61009	30	0	>99	22.8	19	✓	✓		
Out8														
1	61009	C	16	6	61009	30	0	>99	23.4	19	✓	✓		
2	61009	C	16	6	61009	30	0	>99	23.1	19	✓	✓		
3	61009	C	16	6	61009	30	0	>99	23.4	19	✓	✓		
4	61009	C	16	6	61009	30	0	>99	23	25	✓	✓		
5	61009	C	16	6	61009	30	0	>99	23.3	19	✓	✓		
6	61009	C	16	6	61009	30	0	>99	23.3	19	✓	✓		
Out9														
1	61009	C	16	6	61009	30	0	>99	23.1	19	✓	✓		
2	61009	C	16	6	61009	30	0	>99	23.5	21	✓	✓		
3	61009	C	16	6	61009	30	0	>99	23.1	19	✓	✓		
4	61009	C	16	6	61009	30	0	>99	23.6	21	✓	✓		
5	61009	C	16	6	61009	30	0	>99	22.9	19	✓	✓		
6	61009	C	16	6	61009	30	0	>99	23	19	✓	✓		

Out10													
1	61009	C	16	6	61009	30	0	>99	23.2	19	✓	✓	
2	61009	C	16	6	61009	30	0	>99	23.1	19	✓	✓	
3	61009	C	16	6	61009	30	0	>99	23.3	21	✓	✓	
4	61009	C	16	6	61009	30	0	>99	23.6	19	✓	✓	
5	61009	C	16	6	61009	30	0	>99	23	19	✓	✓	
6	61009	C	16	6	61009	30	0	>99	23.1	27	✓	✓	
Out11													
1	61009	C	16	6	61009	30	0	>99	23.3	19	✓	✓	
2	61009	C	16	6	61009	30	0	>99	23.3	19	✓	✓	
3	61009	C	16	6	61009	30	0	>99	23.8	23	✓	✓	
4	61009	C	16	6	61009	30	0	>99	23.7	21	✓	✓	
5	61009	C	16	6	61009	30	0	>99	23.9	25	✓	✓	
6	61009	C	16	6	61009	30	0	>99	23	19	✓	✓	
Out12													
1	61009	C	16	6	61009	30	0	>99	23.8	19	✓	✓	
2	61009	C	16	6	61009	30	0	>99	22.9	17	✓	✓	
3	61009	C	16	6	61009	30	0	>99	23.3	19	✓	✓	
4	61009	C	16	6	61009	30	0	>99	23.3	19	✓	✓	
5	61009	C	16	6	61009	30	0	>99	23.5	21	✓	✓	
6	61009	C	16	6	61009	30	0	>99	23.8	21	✓	✓	
Out13													
1	61009	C	16	6	61009	30	0	>99	23.5	19	✓	✓	
2	61009	C	16	6	61009	30	0	>99	23.3	17	✓	✓	
3	61009	C	16	6	61009	30	0	>99	23.1	19	✓	✓	
4	61009	C	16	6	61009	30	0	>99	23.1	17	✓	✓	
5	61009	C	16	6	61009	30	0	>99	23.5	19	✓	✓	
6	61009	C	16	6	61009	30	0	>99	22.8	17	✓	✓	
Out14													
1	61009	C	16	6	61009	30	0	>99	23.1	19	✓	✓	
2	61009	C	16	6	61009	30	0	>99	23.1	19	✓	✓	
3	61009	C	16	6	61009	30	0	>99	23.6	21	✓	✓	
4	61009	C	16	6	61009	30	0	>99	23.9	19	✓	✓	
5	61009	C	16	6	61009	30	0	>99	23.4	19	✓	✓	
6	61009	C	16	6	61009	30	0	>99	23.3	19	✓	✓	
AUX	61009	C	10	6	61009	30	0	>99	9	21	✓	✓	
Inspected By													
Name	Pierre				Omar								
Signature		Date	18/9/2023										
Test Instrument details : Serial number													Megger MFT1741 1009986102219630