



Certificate Ref: **PDCERT2308190001**

Portable Power Distribution Unit Test and Inspection Certification									
Distribution Board Serial Number or ID				MD63060RCBO0151					
Appliance inlet type		C-Form		Rating (A)		32		1ph	
Loop through outlet type		C-Form		Rating (A)		32		1ph	
Does the loop through output have on board protection				YES				NO	
Main Switch / Switch Fuse/ Circuit Breaker / RCD									
BS(EN)		60898		Breaking Capacity (KA)		6			
No of Poles		4		Fuse /Device rating or setting (A)		32			
If Main Switch is RCD									
Rated residual operating current (ma)				Rated Time delay (ms)		N/A			
Operating time (ms)		X1		X5				ma	
Visual Inspection Satisfactory				Yes		x		No	
If No Give details									
Functional Testing									
Do all MCBs maually operate correctly				YES		x		NO	
If No Give details									
Do all RCD test buttons operate correctly				YES		x		NO	
If No Give details									
Do all circuit indicators operate correctly				YES		x		NO	
If No Give details									
Insulation Resistance Tested at 250V due to sensitive equipment									
L1 - CPC		1.6 Mohm		Satisfactory		x		Yes	
L2 - CPC		2.6 Mohm		Satisfactory		x		Yes	
L3 - CPC		2.55 Mohm		Satisfactory		x		Yes	
N-CPC		1.9 Mohm		Satisfactory		x		Yes	
Polarity throughout Satisfactory				Yes				No	
Test Instrument serial number				1009986102219630					
Inspected By				Usman					
Name		Pierre		Usman					
Signature				Date		19/8/2023			

Certificate Ref: PDCERT2308190001

Schedule of Results														
Distribution Board Serial Number or ID								MD63060RCBO0151						
Circuit Number	RCBO				RCD			Test results				Remarks (Continue on separate sheet if necessary)		
	BS(EN)	Type (B,C,D)	Rating (A)	Breaking Capacity (KA)	BS(EN)	Rating (mA)	Time delay (ms)	RCD trip time x 1/2 (ms)	RCD trip time x 1 (ms) <300	RCD ramp test (mA)	Polarity		Test button operation	
OUT1														
1	61009	C	16	6	61009	30	0	>99	23.9	21	✓	✓		
2	61009	C	16	6	61009	30	0	>99	23.5	19	✓	✓		
3	61009	C	16	6	61009	30	0	>99	23.5	21	✓	✓		
4	61009	C	16	6	61009	30	0	>99	23.4	19	✓	✓		
5	61009	C	16	6	61009	30	0	>99	23.5	19	✓	✓		
6	61009	C	16	6	61009	30	0	>99	23.5	19	✓	✓		
7	61009	C	10	6	61009	30	0	>99	9	21	✓	✓		
8	61009	C	10	6	61009	30	0	>99	9.1	21	✓	✓		
9	61009	C	10	6	61009	30	0	>99	9	21	✓	✓		
10	61009	C	10	6	61009	30	0	>99	8	19	✓	✓		
11	61009	C	10	6	61009	30	0	>99	8	21	✓	✓		
12	61009	C	10	6	61009	30	0	>99	9	23	✓	✓		
										6				
Inspected By														
Name	Pierre			Usman										
Signature				Date	19/8/2023									
Test Instrument details : Serial number							Megger MFT1741 1009986102219630							