


Certificate Ref: **PDCERT2305150001**

Portable Power Distribution Unit Test and Inspection Certification									
Distribution Board Serial Number or ID				MD63100RCD0163					
Appliance inlet type		C-Form		Rating (A)		63		1ph	
Loop through outlet type		C-Form		Rating (A)		63		1ph	
Does the loop through output have on board protection				YES				NO	
Main Switch / Switch Fuse/ Circuit Breaker / RCD									
BS(EN)		60898		Breaking Capacity (KA)		6			
No of Poles		3		Fuse /Device rating or setting (A)		63			
If Main Switch is RCD									
Rated residual operating current (ma)				Rated Time delay (ms)		N/A			
Operating time (ms)		X1		X5				ma	
Visual Inspection Satisfactory				Yes		x		No	
If No Give details									
Functional Testing									
Do all MCBs maually operate correctly				YES		x		NO	
If No Give details									
Do all RCD test buttons operate correctly				YES		x		NO	
If No Give details									
Do all circuit indicators operate correctly				YES		x		NO	
If No Give details									
Insulation Resistance Tested at 250V due to sensitive equipment									
L1 - CPC		1.6 Mohm		Satisfactory		x		Yes	
L2 - CPC		2.6 Mohm		Satisfactory		x		Yes	
L3 - CPC		2.55 Mohm		Satisfactory		x		Yes	
N-CPC		1.9 Mohm		Satisfactory		x		Yes	
Polarity throughout Satisfactory				Yes				No	
Test Instrument serial number				1009986102219630					
Inspected By				Umier					
Name		Pierre		Date		15/5/2023			
Signature									

Certificate Ref: PDCERT2305150001

Schedule of Results													
Distribution Board Serial Number or ID								S/N MD63100RCD0163					
Circuit Number	RCBO				RCD			Test results				Remarks (Continue on separate sheet if necessary)	
	BS(EN)	Type (B,C,D)	Rating (A)	Breaking Capacity (KA)	BS(EN)	Rating (mA)	Time delay (ms)	RCD trip time x 1/2 (ms)	RCD trip time x 1 (ms) <300	RCD ramp test (mA)	Polarity		Test button operation
Out1		A	40	10	61008	30	0	>99			✓	✓	
1	60898	C	16	6			0	>99	26.7	23	✓	✓	
2	60898	C	16	6			0	>99	26.1	25	✓	✓	
3	60898	C	16	6			0	>99	26.3	25	✓	✓	
4	60898	C	16	6			0	>99	26.2	25	✓	✓	
5	60898	C	16	6			0	>99	26.3	25	✓	✓	
6	60898	C	16	6			0	>99	26	25	✓	✓	
Out2		A	63	10	61008	30	0	>99			✓	✓	
1	60898	C	32	6			0	>99	25.9	25	✓	✓	
2	60898	C	32	6			0	>99	25.4	25	✓	✓	
3	60898	C	32	6			0	>99	25.5	25	✓	✓	
4	60898	C	32	6			0	>99	25.3	25	✓	✓	
5	60898	C	32	6			0	>99	25.3	25	✓	✓	
6	60898	C	32	6			0	>99	24.8	25	✓	✓	
Out3		A	40	10	61008	30	0	>99			✓	✓	
1	60898	C	16	6			0	>99	29.7	21	✓	✓	
2	60898	C	16	6			0	>99	29.3	21	✓	✓	
3	60898	C	16	6			0	>99	29.3	21	✓	✓	

Inspected By			
Name	Pierre	Umier	
Signature		Date	15/5/2023

Test Instrument details : Serial number	Megger MFT1741 1009986102219630
---	---------------------------------