

Certificate Ref: **PDCERT2307070003**

Portable Power Distribution Unit Test and Inspection Certification										
Distribution Board Serial Number or ID				MD63210RCD0155						
Appliance inlet type		C-Form		Rating (A)		63		1ph	3ph	x
Loop through outlet type		C-Form		Rating (A)		63		1ph	3ph	x
Does the loop through output have on board protection							YES		NO	x
Main Switch / Switch Fuse/ Circuit Breaker / RCD										
BS(EN)		60898		Breaking Capacity (KA)		6				
No of Poles		4		Fuse /Device rating or setting (A)		63				
If Main Switch is RCD										
Rated residual operating current (ma)				Rated Time delay (ms)		N/A				
Operating time (ms)		X1		X5				ma		
Visual Inspection Satisfactory				Yes		x		No		L1=BROWN, L2=BLACK, L3=GRAY
If No Give details										
Functional Testing										
Do all MCBs maually operate correctly				YES		x		NO		
If No Give details										
Do all RCD test buttons operate correctly				YES		x		NO		
If No Give details										
Do all circuit indicators operate correctly				YES		x		NO		N/A
If No Give details										
Insulation Resistance Tested at 250V due to sensitive equipment										
L1 - CPC		1.6 Mohm		Satisfactory		x		Yes		No
L2 - CPC		2.6 Mohm		Satisfactory		x		Yes		No
L3 - CPC		2.55 Mohm		Satisfactory		x		Yes		No
N-CPC		1.9 Mohm		Satisfactory		x		Yes		No
Polarity throughout Satisfactory				Yes				No		
Test Instrument serial number				1009986102219630						
Inspected By										
Name		Pierre		Umiar						
Signature				Date		2023-07-07				

Certificate Ref: PDCERT2307070003

Schedule of Results													
Distribution Board Serial Number or ID					S/N MD63210RCD0155								
Circuit Number	RCBO				RCD			Test results				Remarks (Continue on separate sheet if necessary)	
	BS(EN)	Type (B,C,D)	Rating (A)	Breaking Capacity (KA)	BS(EN)	Rating (mA)	Time delay (ms)	RCD trip time x 1/2 (ms)	RCD trip time x 1 (ms) <300	RCD ramp test (mA)	Polarity		Test button operation
Out1		A	63	10	61008	30	0	>99			✓	✓	
1	60898	C	32	6			0	>99	24.9	19	✓	✓	
2	60898	C	32	6			0	>99	25	19	✓	✓	
3	60898	C	32	6			0	>99	25	21	✓	✓	
4	60898	C	32	6			0	>99	25	21	✓	✓	
5	60898	C	32	6			0	>99	25	19	✓	✓	
6	60898	C	32	6			0	>99	24.7	19	✓	✓	
Out2		A	40	10	61008	30	0	>99			✓	✓	
1	60898	C	16	6			0	>99	28.2	19	✓	✓	
2	60898	C	16	6			0	>99	28	19	✓	✓	
3	60898	C	16	6			0	>99	27.9	19	✓	✓	
4	60898	C	16	6			0	>99	28.1	19	✓	✓	
5	60898	C	16	6			0	>99	28.2	19	✓	✓	
6	60898	C	16	6			0	>99	28	19	✓	✓	
Out3		A	40	10	61008	30	0	>99			✓	✓	
1	60898	C	32	6			0	>99	29.1	21	✓	✓	
2	60898	C	32	6			0	>99	28.8	21	✓	✓	
3	60898	C	32	6			0	>99	28.8	21	✓	✓	
Out4		A	40	10	61008	30	0	>99			✓	✓	
1	60898	C	32	6			0	>99	25.8	25	✓	✓	
2	60898	C	32	6			0	>99	26.1	25	✓	✓	
3	60898	C	32	6			0	>99	26.5	25	✓	✓	

Inspected By	
Name	Pierre
Signature	Umar
Date	2023-07-07

Test Instrument details : Serial number Megger MFT1741 1009986102219630