



Certificate Ref: **PDCERT2307070004**

Portable Power Distribution Unit Test and Inspection Certification															
Distribution Board Serial Number or ID				MD63210RCD0156											
Appliance inlet type		C-Form		Rating (A)		63		1ph		3ph		x			
Loop through outlet type		C-Form		Rating (A)		63		1ph		3ph		x			
Does the loop through output have on board protection								YES				NO		x	
Main Switch / Switch Fuse/ Circuit Breaker / RCD															
BS(EN)		60898		Breaking Capacity (KA)				6							
No of Poles		4		Fuse /Device rating or setting (A)				63							
If Main Switch is RCD															
Rated residual operating current (ma)								Rated Time delay (ms)				N/A			
Operating time (ms)		X1				X5				ma					
Visual Inspection Satisfactory				Yes		x		No		L1=BROWN, L2=BLACK, L3=GRAY					
If No Give details															
Functional Testing															
Do all MCBs maually operate correctly				YES		x		NO							
If No Give details															
Do all RCD test buttons operate correctly				YES		x		NO							
If No Give details															
Do all circuit indicators operate correctly				YES		x		NO		N/A					
If No Give details															
Insulation Resistance Tested at 250V due to sensitive equipment															
L1 - CPC		1.6		Mohm		Satisfactory		x		Yes		No			
L2 - CPC		2.6		Mohm		Satisfactory		x		Yes		No			
L3 - CPC		2.55		Mohm		Satisfactory		x		Yes		No			
N-CPC		1.9		Mohm		Satisfactory		x		Yes		No			
Polarity throughout Satisfactory				Yes				No							
Test Instrument serial number				1009986102219630											
Inspected By															
Name		Pierre		Umiar											
Signature				Date		2023-07-07									



Certificate Ref: PDCERT2307070004

Schedule of Results													
Distribution Board Serial Number or ID					S/N MD63210RCD0156								
Circuit Number	RCBO				RCD			Test results				Remarks (Continue on separate sheet if necessary)	
	BS(EN)	Type (B,C,D)	Rating (A)	Breaking Capacity (KA)	BS(EN)	Rating (mA)	Time delay (ms)	RCD trip time x 1/2 (ms)	RCD trip time x 1 (ms) <300	RCD ramp test (mA)	Polarity		Test button operation
Out1		A	63	10	61008	30	0	>99			✓	✓	
1	60898	C	32	6			0	>99	26.3	25	✓	✓	
2	60898	C	32	6			0	>99	26	25	✓	✓	
3	60898	C	32	6			0	>99	25.8	21	✓	✓	
4	60898	C	32	6			0	>99	25.8	21	✓	✓	
5	60898	C	32	6			0	>99	25.8	21	✓	✓	
6	60898	C	32	6			0	>99	25.6	21	✓	✓	
Out2		A	40	10	61008	30	0	>99			✓	✓	
1	60898	C	16	6			0	>99	24.8	21	✓	✓	
2	60898	C	16	6			0	>99	24.9	19	✓	✓	
3	60898	C	16	6			0	>99	24.8	19	✓	✓	
4	60898	C	16	6			0	>99	24.9	21	✓	✓	
5	60898	C	16	6			0	>99	25	21	✓	✓	
6	60898	C	16	6			0	>99	24.8	19	✓	✓	
Out3		A	40	10	61008	30	0	>99			✓	✓	
1	60898	C	32	6			0	>99	25.5	25	✓	✓	
2	60898	C	32	6			0	>99	25.3	21	✓	✓	
3	60898	C	32	6			0	>99	25.1	21	✓	✓	
Out4		A	40	10	61008	30	0	>99			✓	✓	
1	60898	C	32	6			0	>99	25.5	23	✓	✓	
2	60898	C	32	6			0	>99	25.3	23	✓	✓	
3	60898	C	32	6			0	>99	25.5	23	✓	✓	

Inspected By			
Name	Pierre	Umar	
Signature		Date	2023-07-07

Test Instrument details : Serial number	Megger MFT1741 1009986102219630
---	---------------------------------

