

Certificate Ref:PDCERT2208170002

Portable Power Distribution Unit Test and Inspection Certification									
Distribution Board Serial Number or ID				MD63351RCD0156					
Appliance inlet type		C-Form		Rating (A)		63		1ph	
Loop through outlet type				Rating (A)				1ph	
Does the loop through output have on board protection				YES				NO	
Main Switch / Switch Fuse/ Circuit Breaker / RCD									
BS(EN)		60898		Breaking Capacity (KA)		6			
No of Poles		4		Fuse /Device rating or setting (A)		63			
If Main Switch is RCD									
Rated residual operating current (ma)				Rated Time delay (ms)		N/A			
Operating time (ms)		X1		X5				ma	
Visual Inspection Satisfactory				Yes		x		No	
If No Give details									
Functional Testing									
Do all MCBs maually operate correctly				Yes		x		No	
If No Give details									
Do all RCD test buttons operate correctly				Yes		x		No	
If No Give details									
Do all circuit indicators operate correctly				Yes		x		No	
If No Give details									
Insulation Resistance Tested at 250V due to sensitive equipment									
L1 - CPC		Mohm		Satisfactory		x		Yes	
L2 - CPC		Mohm		Satisfactory		x		Yes	
L3 - CPC		Mohm		Satisfactory		x		Yes	
N-CPC		Mohm		Satisfactory		x		Yes	
Polarity throughout Satisfactory				Yes		x		No	
Test Instrument serial number				1009986102219630					
Inspected By									
Name		Maroun Razzouk		Georges Germanos					
Signature				Date		23/11/2022			

Certificate Ref: PDCERT2208170002

Schedule of Results

Distribution Board Serial Number or ID

MD63310RCD0156

RCBO															
Over current device					RCD			Test results						Remarks (Continue on separate sheet if necessary)	
Circuit Number	BS(EN)	Type (B,C,D)	Rating (A)	Breaking Capacity (KA)	BS(EN)	Rating (mA)	Time delay (ms)	RCD trip time x 1/2 (ms)	RCD trip time x 1 (ms) <300	RCD trip time x 5 (ms) <40	RCD ramp test (mA)	Polarity	Test button operation		
Out1 1		A	40	10	61008	30	0	>99				✓	✓		
1	60898	C	16	6			0	>99	25.1	6.9	21	✓	✓		
2	60898	C	16	6			0	>99	24.9	6.9	21	✓	✓		
3	60898	C	16	6			0	>99	24.9	6.9	21	✓	✓		
4	60898	C	16	6			0	>99	25.1	6.9	21	✓	✓		
5	60898	C	16	6			0	>99	24.9	6.9	21	✓	✓		
6	60898	C	16	6			0	>99	24.9	6.9	21	✓	✓		
Out1 2		A	40	10	61008	30	0	>99				✓	✓		
1	60898	C	16	6			0	>99	24.3	6.6	23	✓	✓		
2	60898	C	16	6			0	>99	24.3	6.6	23	✓	✓		
3	60898	C	16	6			0	>99	24.4	6.5	23	✓	✓		
4	60898	C	16	6			0	>99	24.3	6.6	23	✓	✓		
5	60898	C	16	6			0	>99	24.3	6.6	23	✓	✓		
6	60898	C	16	6			0	>99	24.4	6.5	23	✓	✓		
Aux	60898	C	10	6			0	>99				✓	✓		
Inspected By															
Name	Maroun Razzouk			Georges Germanos											
Signature				Date	23/11/2022										
Test Instrument details : Serial number						Megger MFT1741 1009986102219630									