



Certificate Ref: **PDCERT2307080004**

Portable Power Distribution Unit Test and Inspection Certification									
Distribution Board Serial Number or ID				MD32130RCD0156					
Appliance inlet type		Not A/V		Rating (A)		1ph		3ph	
Loop through outlet type		Not A/V		Rating (A)		1ph		3ph	
Does the loop through output have on board protection						YES		NO	
Main Switch / Switch Fuse/ Circuit Breaker / RCD									
BS(EN)		Not A/V		Breaking Capacity (KA)					
No of Poles				Fuse /Device rating or setting (A)					
If Main Switch is RCD									
Rated residual operating current (ma)			Rated Time delay (ms)			N/A			
Operating time (ms)		X1		X5		ma			
Visual Inspection Satisfactory				Yes	<input checked="" type="checkbox"/>	No		L1=BROWN, L2=BLACK, L3=GREY	
If No Give details									
Functional Testing									
Do all MCBs maually operate correctly				YES	<input checked="" type="checkbox"/>	NO			
If No Give details									
Do all RCD test buttons operate correctly				YES	<input checked="" type="checkbox"/>	NO			
If No Give details									
Do all circuit indicators operate correctly				YES	<input checked="" type="checkbox"/>	NO		N/A	
If No Give details									
Insulation Resistance Tested at 250V due to sensitive equipment									
L1 - CPC		Mohm	Satisfactory	<input checked="" type="checkbox"/>	Yes			No	
L2 - CPC		Mohm	Satisfactory	<input checked="" type="checkbox"/>	Yes			No	
L3 - CPC		Mohm	Satisfactory	<input checked="" type="checkbox"/>	Yes			No	
N-CPC		Mohm	Satisfactory	<input checked="" type="checkbox"/>	Yes			No	
Polarity throughout Satisfactory				Yes		No			
Test Instrument serial number			1009986102219630						
Inspected By									
Name		Pierre							
Signature					Date		2023-08-07		



Certificate Ref: PDCERT2307080004

Schedule of Results													
Distribution Board Serial Number or ID							DB32130RCD0156						
Circuit Number	RCBO				RCD			Test results					Remarks (Continue on separate sheet if necessary)
	BS(EN)	Type (B,C,D)	Rating (A)	Breaking Capacity (KA)	BS(EN)	Rating (mA)	Time delay (ms)	RCD trip time x 1/2 (ms)	RCD trip time x 1 (ms) <300	RCD ramp test (mA)	Polarity	Test button operation	
<b>Out1</b>		<b>A</b>	40	10	61008	30	0	>99			✓	✓	
1	60898	C	32	6			0	>99	28.2	21	✓	✓	
2	60898	C	32	6			0	>99	28.2	19	✓	✓	
3	60898	C	32	6			0	>99	28.3	21	✓	✓	
<b>Inspected By</b>													
Name	Pierre												
Signature				Date	2023-08-07								
Test Instrument details : Serial number							Megger MFT1741 1009986102219630						

