



Certificate Ref: **PDCERT2307040005**

Portable Power Distribution Unit Test and Inspection Certification										
Distribution Board Serial Number or ID					DBC163P04RCD0155					
Appliance inlet type			Not A/V		Rating (A)		1ph	3ph		
Loop through outlet type			Not A/V		Rating (A)		1ph	3ph		
Does the loop through output have on board protection							YES	NO		
Main Switch / Switch Fuse/ Circuit Breaker / RCD										
BS(EN)		Not A/V		Breaking Capacity (KA)						
No of Poles		Fuse /Device rating or setting (A)								
If Main Switch is RCD										
Rated residual operating current (ma)			Rated Time delay (ms)			N/A				
Operating time (ms)		X1	X5				ma			
Visual Inspection Satisfactory				Yes	<input checked="" type="checkbox"/>	No	L1=BROWN, L2=BLACK, L3=GREY			
If No Give details										
Functional Testing										
Do all MCBs maually operate correctly				YES	<input checked="" type="checkbox"/>	NO				
If No Give details										
Do all RCD test buttons operate correctly				YES	<input checked="" type="checkbox"/>	NO				
If No Give details										
Do all circuit indicators operate correctly				YES	<input checked="" type="checkbox"/>	NO	N/A			
If No Give details										
Insulation Resistance Tested at 250V due to sensitive equipment										
L1 - CPC		Mohm	Satisfactory	<input checked="" type="checkbox"/>	Yes				No	
L2 - CPC		Mohm	Satisfactory	<input checked="" type="checkbox"/>	Yes				No	
L3 - CPC		Mohm	Satisfactory	<input checked="" type="checkbox"/>	Yes				No	
N-CPC		Mohm	Satisfactory	<input checked="" type="checkbox"/>	Yes				No	
Polarity throughout Satisfactory				Yes	No					
Test Instrument serial number			1009986102219630							
Inspected By										
Name		Pierre								
Signature					Date	2023-04-07				



Certificate Ref: PDCERT2307040005

Schedule of Results													
Distribution Board Serial Number or ID						DBC163P04RCD0155							
Circuit Number	RCBO				RCD			Test results					Remarks (Continue on separate sheet if necessary)
	Over current device												
	BS(EN)	Type (B,C,D)	Rating (A)	Breaking Capacity (KA)	BS(EN)	Rating (mA)	Time delay (ms)	RCD trip time x 1/2 (ms)	RCD trip time x 1 (ms) <300	RCD ramp test (mA)	Polarity	Test button operation	
<b>Out1</b>		<b>A</b>	25	6	61008	30	0	>99			✓	✓	
<b>1</b>	60898	C	16	6			0	>99	<b>26.9</b>	<b>21</b>	✓	✓	
<b>Inspected By</b>													
<b>Name</b>		Pierre											
<b>Signature</b>				<b>Date</b>		2023-04-07							
<b>Test Instrument details : Serial number</b>						Megger MFT1741 1009986102219630							

