





Certificate Ref: **PDCERT2306170003**

Portable Power Distribution Unit Test and Inspection Certification										
Distribution Board Serial Number or ID				DBM63184RCD0152						
Appliance inlet type		C-FORM		Rating (A)		63		1ph	3ph	x
Loop through outlet type				Rating (A)				1ph	3ph	
Does the loop through output have on board protection							YES		NO	
Main Switch / Switch Fuse/ Circuit Breaker / RCD										
BS(EN)		60898		Breaking Capacity (KA)		6				
No of Poles		3		Fuse /Device rating or setting (A)		63				
If Main Switch is RCD										
Rated residual operating current (ma)				Rated Time delay (ms)		N/A				
Operating time (ms)		X1		X5				ma		
Visual Inspection Satisfactory				Yes	x	No			L1=BROWN, L2=BLACK, L3=GREY	
If No Give details										
Functional Testing										
Do all MCBs maually operate correctly				YES	x	NO				
If No Give details										
Do all RCD test buttons operate correctly				YES	x	NO				
If No Give details										
Do all circuit indicators operate correctly				YES	x	NO	N/A			
If No Give details										
Insulation Resistance Tested at 250V due to sensitive equipment										
L1 - CPC	1.4	Mohm	Satisfactory	x	Yes				No	
L2 - CPC	1.8	Mohm	Satisfactory	x	Yes				No	
L3 - CPC	2.2	Mohm	Satisfactory	x	Yes				No	
N-CPC	1.8	Mohm	Satisfactory	x	Yes				No	
Polarity throughout Satisfactory				Yes		No				
Test Instrument serial number				1009986102219630						
Inspected By										
Name		Pierre			Viraj					
Signature					Date		17/6/2023			



Certificate Ref: PDCERT2306170003

Schedule of Results													
Distribution Board Serial Number or ID						DBM63184RCD0152							
Circuit Number	RCBO				RCD			Test results					Remarks (Continue on separate sheet if necessary)
	BS(EN)	Type (B,C,D)	Rating (A)	Breaking Capacity (KA)	BS(EN)	Rating (mA)	Time delay (ms)	RCD trip time x 1/2 (ms)	RCD trip time x 1 (ms) <300	RCD ramp test (mA)	Polarity	Test button operation	
Out1		A	40	10	61008	30	0	>99			✓	✓	
1	60898	C	16	6			0	>99	25.7	25	✓	✓	
2	60898	C	16	6			0	>99	25.8	25	✓	✓	
3	60898	C	16	6			0	>99	25.9	25	✓	✓	
4	60898	C	16	6			0	>99	26	25	✓	✓	
5	60898	C	16	6			0	>99	25.9	25	✓	✓	
6	60898	C	16	6			0	>99	25.8	25	✓	✓	
Out2		A	40	10	61008	30	0	>99			✓	✓	
1	60898	C	16	6			0	>99	26	23	✓	✓	
2	60898	C	16	6			0	>99	25.9	23	✓	✓	
3	60898	C	16	6			0	>99	25.6	23	✓	✓	
4	60898	C	16	6			0	>99	25.7	23	✓	✓	
5	60898	C	16	6			0	>99	25.8	23	✓	✓	
6	60898	C	16	6			0	>99	25.7	23	✓	✓	
Out3		A	40	10	61008	30	0	>99			✓	✓	
1	60898	C	32	6			0	>99	25.6	23	✓	✓	
2	60898	C	32	6			0	>99	25.5	21	✓	✓	
3	60898	C	32	6			0	>99	25.3	21	✓	✓	
Inspected By													
Name	Pierre				Viraj								
Signature					Date	17/6/2023							
Test Instrument details : Serial number						Megger MFT1741 1009986102219630							